

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI-110 001.**

No.F.6/DFS/MS/School/2024/SZ/ 205

Dated: 15/03/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Dhruva Public Sr. Sec. School**, G-11, Jai Vihar, Baprola, New Delhi-110043, having two blocks namely Old Block & New Block. Old Block is comprised of ground plus two upper floor & New Block is comprised of ground plus three upper floors (Previous FSC issued by this department vide letter No. F.6/DFS/MS/School/2021/SZ/412 dated 28.06.2021 for ground plus one upper floor only for old block) owned/occupied by Dhruva Public School have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 04.03.2024 in the presence of Mrs. Rekha (Principal) and that the building is fit for occupancy class "**Educational**" with effect from **15/03/2024** for a period of **three** years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on.....**15/03/2024**.....at New Delhi by.

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to:-

1. The Manager, Dhruva Public Sr. Sec. School, G-11, Jai Vihar, Baprola, New Delhi- 43.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi – 110054.

**Following fire safety directives must be adhered to:-**

- The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- All the means of escape shall be kept free of all the type of obstruction all the time.
- All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
- All the fire-fighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
- The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
- This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- \* The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

*Rekha*  
Principal  
DHRUVA PUBLIC SCHOOL  
(A Recognised School)  
Jai Vihar, New Delhi- 110043

*Saloni*  
Manager  
DHRUVA PUBLIC SCHOOL  
Jai Vihar, Noida, New Delhi